

## STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

DAVID A. COLE
COMMISSIONER

August 16, 2004 Subject: Eliot Project No. STP-8144(00)X PIN 8144.00 Bid Amendment No. 2

Dear Sir/Ms.:

Please make the following changes to the Bid Documents:

On page 2 of the "Schedule of Items" Line No 0180 603.169 375 mm "Culvert Pipe Option III" 48.000 M, delete 48.000 M and replace with 56.000 M.

On page 2 of the "Schedule of Items" Line No 0190 603.179 450 mm "Culvert Pipe Option III" 79.000 M, delete 79.000 M and replace with 71.000 M.

Make these changes in pen and ink.

Please make the following changes to the Plan Sheets:

On Plan sheet No. 3 of 79 entitled "Estimated Quantities & Earthwork Summery" under the "Estimated Quantities" Item No.603.169 375 mm "Culvert Pipe Option III" 48.000 M delete **48.000** M and replace with **56.000** M.

On Plan sheet No. 3 of 79 entitled "Estimated Quantities & Earthwork Summery" under the "Estimated Quantities" Item No. 603.179 450 mm "Culvert Pipe Option III" 79.000 M delete **79.000 M** and replace with **71.000** M.

On Plan sheet No 4 of 79 entitled "Drainage Sheet" Cross Pipes- for C.B. # 8 TO C.B. # 7, under Smoothlined, change the length of 450 to now read 375, under Corrugated change the size of 525 to now read 450.

On Plan Sheets No's 8 of 79 and 32 of 79 change 450 mm Culvert Pipe Option III to now read 375mm Culvert Pipe Option III.

Make these changes in pen and ink.

The Department has received the following request for information:

- Q) After the pavement is removed, under Item 310.23, it would appear from the Cross Sections that it will be necessary to adjust the existing road base by the addition of aggregates to achieve the required grade and cross slope, how will this be paid?
- A) Additional material necessary to adjust the existing grade & cross slope is included in the estimated quantity for Item 304.10 "Aggregate Subbase Course-Gravel."

- Q) Item No. 603.159 bid quantities do not agree with plans or the drainage sheet, can you indicate which is correct?
- **A)** Please refer to General Note # 23 regarding reestablishment of existing drainage at Station 1+246.

Consider this information and changes prior to submitting your bid on August 18, 2004.

Sincerely

Scott Bickford

Contracts & Specifications Engineer